



REACTION TO FIRE CLASSIFICATION REPORT  
N° 2015/062-2  
(English version of classification report N°2015/062-1)  
According to EN 13501-1 (2007) + A1 (2013)

Notification by the French Government to the European Commission  
under n° NB 2401  
Regulation (UE) n° 305/2011

Sponsor : IVC NV  
Nijverheidslaan 29  
8580 AVELGEM  
BELGIUM

Product group : JUMBO LEOLINE ITEC  
(Update)

Description : Resilient floor covering (EN 653 family)  
(see detailed description in paragraph 2)

Date of issue : 12/01/2017

*The indicated classification does not prejudice the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption's code of the law dated June 3<sup>rd</sup> 1994.*

*The reproduction of this classification report is only authorised in its integral form.  
It comprise 4 pages*

**1. Introduction**

This classification report defines the classification assigned to the above-mentioned product (s) in accordance with the procedures given in the NF EN 13501-1 standard: September 2007 & A1 (2013).

**2. Details of classified product**2.1. Product standard

NF EN 14041 (2005):“Resilient, textile and laminate floor coverings - Essential characteristics”.

2.2. Product description

Expanded polyvinyl chloride floor covering (EN 653 family).

Tested loose laid over a fibre-cement board classified A1<sub>fl</sub> or A2<sub>fl</sub> with a density (1800 ± 200) kg/m<sup>3</sup> and thickness (8 ± 2) mm.

Use surface: 100 % PVC

Nominal mass per unit area : 1425 g/m<sup>2</sup> - 2368 g/m<sup>2</sup>

Nominal total thickness : 2,20 mm – 4,00 mm

Nominal wear layer thickness : 0,12 mm – 0,50 mm

**3. Test reports and tests results in support of this classification**3.1. Tests reports

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	IVC NV Nijverheidslaan 29 8580 AVELGEM BELGIUM	RL 2015/390 RL 2015/391	NF EN ISO 9239-1

3.2. Tests results

Classes of reaction to fire for textile floor coverings, classified without further testing.

Test method	The floorings of product group « <b>JUMBO LEOLINE ITEC</b> » meet the requirements of table 3 of the standard NF EN 14041 (2005) and are classified without further testing (CWFT)
NF EN ISO 11925-2	<b>Classification E<sub>fl</sub></b>

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	ACE	3	Critical heat flux (kW/m <sup>2</sup> )	6,6
			Smoke (% X min)	131,0

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	SUPERCOMFORT	3	Critical heat flux (kW/m <sup>2</sup> )	6,5
			Smoke (% X min)	174,7

#### 4. Classification and field of application

##### 4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-1 :2007 & A1 (2013).

##### 4.2. Classification

Fire behaviour		Smoke production
C <sub>fl</sub>	-	s1

**Classification : C<sub>fl</sub> – s1**

##### 4.3. Field of application

This classification is valid for the following end use applications :

Loose laid and glued over a fibre-cement A2<sub>fl</sub> or A1<sub>fl</sub> class with a density  $\geq 1350$  kg/m<sup>3</sup>

This classification is valid for the following product parameters :

- A nominal mass per unit area of: 1425 g/m<sup>2</sup> - 2368 g/m<sup>2</sup>
- A nominal thickness of : 2,20 mm – 4,00 mm
- A nominal wear layer thickness: 0,12 mm – 0,50 mm
- 

**The classification of the product family is valid for the following trademarks :**

ACE  
AERO  
ATHENA  
BATIPRO  
CAPPUBLITZ  
CAPPUCCINO  
DOLCE VITA  
ECOWOOD  
IMPACT  
IMPULSE  
ITEC 350  
INVENT  
INVENT TREND  
LUXURY CLASSICS  
LUXURY TRENDS  
LUXURY WOODS

MATRIX  
NOVA  
REVELATIONS  
SILENTO  
SILENTO DESIGN  
SILENTO WOODS  
SUPERCOMFORT  
SUPERCOMFORT BLITZ  
SUNDERLAY  
TILES STYLES  
ULTIMATE ELEMENTS  
ULTIMATE IMPRESSIONS  
ULTIMATE MINERALS  
VICTORIA  
VIGAN  
WIZZART  
WOODLIKE  
WOODMARK SR

## 5. Limitations

This classification document does not represent type approval or certification of the product.

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.”

For the SARL C.R.E.T.  
The Technical Director  
Marc WELCOMME



*End of the classification report*